



House of Assembly
Nova Scotia

RECEIVED

OCT 21 2014

Constituency Office Barrier-free Compliance Plan

MLA Name Randy Delorey Constituency Antigonish

Street 155 Main Street, Suite 202

Municipality Antigonish Postal Code B2G 2B6

My Office is Barrier-free

I certify my constituency office meets the barrier-free requirements as outlined in the House of Assembly Management Commission Regulations.

MLA Signature [Signature] Submission Date 2014-10-17

My constituency office is not Barrier-free

I confirm that my constituency office is not compliant with the barrier-free requirements. I understand that I can continue to occupy the non-compliant space only on a month-to-month basis for a maximum of 12 months and that I must set out below my plan to render the space compliant with the barrier-free requirements during the 12 month-to-month period. My office is not barrier-free for the following reasons:

I intend to do the following to remedy the non-compliant reasons listed above

MLA Signature _____ Review [Signature] Approved [Signature]

Submission Date _____ Date Oct 17/14 Date Oct 16/14

Notes
Request for technical variances submitted: (1) building has audible alarm but not visual alarm (2) Office entrance clear opening is 787mm vs regulation "Minimum clear opening width when door is open position 800mm"

Barrier-free Check List

- | | | |
|---|--|--|
| Parking <ul style="list-style-type: none"> • Paved Lot • One van-accessible space with signage Barrier Free approach <ul style="list-style-type: none"> • Curb cut • Ramp • Sidewalk | Meeting Space and general accessibility <ul style="list-style-type: none"> • Braille signs • Sized and spaced for accessibility • Audible and visible alarms Doors and entrance <ul style="list-style-type: none"> • Level threshold (may include ramp or elevator) • 1000 mm width • Sized and spaced for accessibility • 2 kg door opening pressure or power door | Washrooms <ul style="list-style-type: none"> • Raised toilet • Accessible sink • Sized and spaced for accessibility • Grab bars • Appropriate dispensers • Installed at correct height • Braille signs |
|---|--|--|

A more detailed checklist is available on the Members Only site at nslegislature.ca/index.php/login