



House of Assembly  
Nova Scotia

## Constituency Office Barrier-free Compliance Plan

MLA Name Timothy Halman Constituency Dartmouth East  
Street 99 Main Street, suite 1  
Municipality Dartmouth Postal Code B2X 1R4

### MY OFFICE IS BARRIER-FREE

I certify my constituency office meets the barrier-free requirements as outlined in the House of Assembly Management Commission Regulations.

MLA Signature \_\_\_\_\_ Submission Date \_\_\_\_\_

### MY CONSTITUENCY OFFICE IS NOT BARRIER-FREE

I confirm that my constituency office is not compliant with the barrier-free requirements. I understand that I may continue to occupy the non-compliant space only on a month-to-month basis for a maximum of 12 months and that I must set out below my plan to render the space compliant with the barrier-free requirements during the 12 month-to-month period.

My office is not barrier-free for the following reasons:

No Braille sign at the entrance.  
No grab bars in the washroom, also no Braille sign on the washroom door.  
No automatic door.

I intend to do the following to remedy the non-compliant reasons listed above:

We will order Braille signs for the entrance and the washroom.  
The landlord will be installing a grab bar in the washroom.  
The landlord will be installing an automatic door with an additional ramp.

MLA Signature

T. Halman

Submission Date

June 10, 2024

Review

[Signature]  
Director of Administration

Date

Nov 25/24

Approved

[Signature]  
The Honourable The Speaker

Date 26-11-2024

### Barrier-free Check List

#### Parking

- Paved Lot ✓
- One van-accessible space with signage ✓

#### Barrier Free approach

- Curb cut ✓
- Ramp ✓
- Sidewalk ✓

#### Meeting Space and general accessibility

- Braille signs
- Sized and spaced for accessibility ✓
- Audible and visible alarms ✓

#### Doors and entrance

- Level threshold (may include ramp or elevator) ✓
- Sized and spaced for accessibility ✓
- 2 kg door opening pressure or power floor

#### Washrooms

- Raised toilet ✓
- Accessible sink ✓
- Sized and spaced for accessibility ✓
- Grab bars
- Appropriate dispensers ✓
- Installed at correct height
- Braille signs

A more detailed checklist is available on the Members Only site at [nslc.qislature.ca/index.php/login](https://nslc.qislature.ca/index.php/login)

Rev 17Dec2015